



**JEFFERSON COUNTY  
FIRE PREVENTION AND BUILDING CODE OFFICE**

175 ARSENAL STREET  
WATERTOWN, NEW YORK 13601  
E-mail: [codeenforcement@co.jefferson.ny.us](mailto:codeenforcement@co.jefferson.ny.us)

Telephone: (315) 785-5130

Fax: (315) 785-5131

**SOLAR PERMIT APPLICATION**

Dear Applicant:

Attached is a Jefferson County Solar Permit Application and Fee Schedule. This application is for use only in communities where the County of Jefferson is responsible for enforcement of the Building Codes of New York State. The permit applied for with this form applies only to the Building Codes of New York State and has no bearing on the other local, State, or Federal regulations, such as zoning or floodplain ordinances, etc.

The permit fee must be submitted to the Jefferson County Code Office with completed application. Please make all checks payable to Jefferson County and mailed to the Jefferson County Code Enforcement Department, 175 Arsenal Street, Watertown, NY 13601.

The approved permit and all correspondence will be mailed to the owner at the address indicated on the application.

It is the responsibility of the owner to see that the Jefferson County Code Enforcement Officer is notified when the project will be ready for the next inspection.

**If you have any questions, please contact the Jefferson County Code Enforcement Office at 315-785-5130.**

## PERMIT APPLICATION

# NY State Unified Solar Permit

Unified solar permitting is available statewide for eligible solar photovoltaic (PV) installations. Municipal authorities that adopt the unified permit streamline their process while providing consistent and thorough review of solar PV permitting applications and installations. Upon approval of this application and supporting documentation, the authority having jurisdiction (AHJ) will issue a building and/or electrical permit for the solar PV installation described herein.

### PROJECT ELIGIBILITY FOR UNIFIED PERMITTING PROCESS

By submitting this application, the applicant attests that the proposed project meets the established eligibility criteria for the unified permitting process (subject to verification by the AHJ). The proposed solar PV system installation:

- Yes  No 1. Has a rated DC capacity of 25 kW or less.
- Yes  No 2. Is not subject to review by an Architectural or Historical Review Board. (If review has already been issued answer YES and attach a copy)
- Yes  No 3. Does not need a zoning variance or special use permit.  
(If variance or permit has already been issued answer YES and attach a copy)
- Yes  No 4. Is mounted on a permitted roof structure, on a legal accessory structure, or ground mounted on the applicant's property. If on a legal accessory structure, a diagram showing existing electrical connection to structure is attached.
- Yes  No 5. The Solar Installation Contractor complies with all licensing and other requirements of the jurisdiction and the State.
- Yes  No 6. If the structure is a sloped roof, solar panels are mounted parallel to the roof surface.
- Yes  No 7. For roof mounted solar panels you must provide a letter from a Professional Engineer or Registered Architect certifying that the existing structure can support the additional weight and wind loads of the solar electric system.

For solar PV systems not meeting these eligibility criteria, the applicant is not eligible for the Unified Solar Permit and must submit conventional permit applications. Permit applications may be downloaded here:

<https://co.jefferson.ny.us/departments/CodeEnforcement> or obtained in person at Jefferson County Code Enforcement, 175 Arsenal Street, Watertown, NY during business regular hours.

### SUBMITTAL INSTRUCTIONS

For projects meeting the eligibility criteria, this application and the following attachments will constitute the Unified Solar Permitting package.

- This application form, with all fields completed and bearing relevant signatures.
- Permitting fee of \$80.00, payable by cash, check or credit card, checks should be made payable to Jefferson County and mailed to Jefferson County Code Enforcement, 175 Arsenal Street, Watertown, NY 13601.
- Required Construction Documents for the solar PV system type being installed, including required attachments.

Completed permit applications can be submitted electronically to [codeenforcement@co.jefferson.ny.us](mailto:codeenforcement@co.jefferson.ny.us) or in person at Jefferson County Code Enforcement, 175 Arsenal Street, Watertown, NY 13601 during normal business hours.

### APPLICATION REVIEW TIMELINE

Permit determinations will be issued within 14 calendar days upon receipt of complete and accurate applications. The municipality will provide feedback within 7 calendar days of receiving incomplete or inaccurate applications.

### FOR FURTHER INFORMATION

Questions about this permitting process may be directed to Jefferson County Code Enforcement 315-785-5130.

## PROPERTY OWNER

Property Owner's First Name

Last Name

Title

Property Address

City

State

Zip

Section

Block

Lot Number

## EXISTING USE

Single Family

2-4 Family

Commercial

Other

## PROVIDE THE TOTAL SYSTEM CAPACITY RATING (SUM OF ALL PANELS)

Solar PV System: \_\_\_\_\_ kW DC

## SELECT SYSTEM CONFIGURATION

Make sure your selection matches the Construction Documents included with this application.

Supply side connection with microinverters

Load side connection with DC optimizers

Supply side connection with DC optimizers

Load side connection with microinverters

Supply side connection with string inverter

Load side connection with string inverter

## SOLAR INSTALLATION CONTRACTOR

Contractor Business Name

Contractor Business Address

City

State

Zip

Contractor Contact Name

Phone Number

Contractor Email

Electrician Business Name

Electrician Business Address

City

State

Zip

Electrician Contact Name

Phone Number

Electrician Email

Please sign below to affirm that all answers are correct and that you have met all the conditions and requirements to submit a unified solar permit.

Property Owner's Signature

Date

Solar Installation Company Representative Signature

Date

## SUBMITTAL REQUIREMENTS SOLAR PV 25KW OR LESS (ATTACHMENTS)

# NY State Unified Solar Permit

This information bulletin is published to guide applicants through the unified solar PV permitting process for solar photovoltaic (PV) projects 25 kW in size or smaller. This bulletin provides information about submittal requirements for plan review, required fees, and inspections.

### PERMITS AND APPROVALS REQUIRED

The following permits are required to install a solar PV system with a nameplate DC power output of 25 kW or less:

- a) Unified Solar Permit
- b) Zoning approval from the local municipality may also be required. Confirm with the local Zoning Officer, and provide this office with a copy of approval if required.

c) Building Code review is required for solar PV installations of this size.

Fire Department approval is not required for solar PV installations of this size.

### SUBMITTAL REQUIREMENTS

In order to submit a complete permit application for a new solar PV system, the applicant must include:

- a) Completed Standard Permit Application form which includes confirmed eligibility for the Unified Solar Permitting process. This permit application form can be downloaded at <https://co.jefferson.ny.us/departments/CodeEnforcement>.
- b) Construction Documents must be stamped and signed by a New York State Registered Architect or New York State Licensed Professional Engineer.

Jefferson County, through adopting the Unified Solar Permitting process, requires contractors to provide construction documents, such as the examples included in the Understanding Solar PV Permitting and Inspecting in New York State document. Should the applicant wish to submit Construction Documents in another format, ensure that the submittal includes the following information:

- Manufacturer/model number/quantity of solar PV modules and inverter(s).
- String configuration for solar PV array, clearly indicating the number of modules in series and strings in parallel (if applicable).
- Combiner boxes: Manufacturer, model number, NEMA rating.
- From array to the point of interconnection with existing (or new) electrical distribution equipment: identification of all raceways (conduit, boxes, fittings, etc.), conductors and cable assemblies, including size and type of raceways, conductors, and cable assemblies.
- Sizing and location of the EGC (equipment grounding conductor).
- Sizing and location of GEC (grounding electrode conductor, if applicable).
- Disconnecting means of both AC and DC including indication of voltage, ampere, and NEMA rating.
- Interconnection type/location (supply side or load side connection)
- For supply side connections only, indication that breaker or disconnect meets or exceeds available utility fault current rating kAIC (amps interrupting capacity in thousands).
- Ratings of service entrance conductors (size insulation type AL or CU), proposed service disconnect, and overcurrent protection device for new supply side connected solar PV system (reference NEC 230.82, 230.70).
- Rapid shutdown device location/method and relevant labeling.

c) (For Roof Mounted Systems) A roof plan showing roof layout, solar PV panels and the following fire safety items: approximate location of roof access point, location of code-compliant access pathways, code exemptions, solar PV system fire classification, and the locations of all required labels and markings.

d) Provide construction drawings with the following information:

- The type of roof covering and the number of roof coverings installed.
- Type of roof framing, size of members, and spacing.
- Weight of panels, support locations, and method of attachment.
- Framing plan and details for any work necessary to strengthen the existing roof structure.
- Site-specific structural calculations.

e) Where an approved racking system is used, provide documentation showing manufacturer of the racking system, maximum allowable weight the system can support, attachment method to roof or ground, and product evaluation information or structural design for the rack.

## PLAN REVIEW

Permit applications can be submitted to Jefferson County Code Enforcement in person at 175 Arsenal Street, Watertown NY 13601 and electronically through: [codeenforcement@co.jefferson.ny.us](mailto:codeenforcement@co.jefferson.ny.us) or fax 315-785-5131.

## FEES

Permit fee of \$80.00

## INSPECTIONS

Once all permits to construct the solar PV installation have been issued and the system has been installed, it must be inspected before final approval is granted for the solar PV system. On-site inspections can be scheduled by contacting Code Enforcement by telephone at 315-785-5130 or electronically at [codeenforcement@co.jefferson.ny.us](mailto:codeenforcement@co.jefferson.ny.us). Inspection requests received within business hours are typically scheduled for the next business day. If next business day is not available, inspection should happen within a five-day window.

In order to receive final approval, the following inspections are required:

**ROUGH INSPECTION, IF REQUIRED:** During a rough inspection, the applicant must demonstrate that the work in progress complies with relevant codes and standards. The purpose of the rough inspection is to allow the inspector to view aspects of the system that may be concealed once the system is complete, such as:

- Portions of the system that are contained in trenches or foundations that will be buried upon completion of the system.

**THIRD PARTY ELECTRICAL INSPECTION:** An electrical inspection by a Jefferson County Code Office approved electrical inspector shall be performed and final electrical certificate shall be provided.

It is the responsibility of the applicant to notify Jefferson County Code Enforcement before the components are buried or concealed and to provide safe access (including necessary climbing and fall arrest equipment) to the inspector. The inspector will attempt, if possible, to accommodate requests for rough inspections in a timely manner.

**FINAL INSPECTION:** The applicant must contact Jefferson County Code Enforcement when ready for a final inspection. During this inspection, the inspector will review the complete installation to ensure compliance with codes and standards, as well as confirming that the installation matches the records included with the permit application. The applicant must have ready, at the time of inspection, the following materials and make them available to the inspector:

- Copies of as-built drawings and equipment specifications, if different than the materials provided with the application.
- Photographs of key hard to access equipment, including;
  - Example of array attachment point and flashing/sealing methods used.
  - Opened rooftop enclosures, combiners, and junction boxes.
  - Bonding point with premises grounding electrode system.
  - Supply side connection tap method/device.
  - Module and microinverter/DC optimizer nameplates.
  - Microinverter/DC optimizer attachment.

The applicant should be prepared to show compliance with the following:

- Number of solar PV modules and model number match plans and specification sheets number match plans and specification sheets.
- Array conductors and components are installed in a neat and workman-like manner.
- Solar PV array is properly grounded.
- Electrical boxes and connections are suitable for environment.
- Array is fastened and sealed according to attachment detail.
- Conductor's ratings and sizes match plans.
- Appropriate signs are property constructed, installed and displayed, including the following:
  - Sign identifying PV power source system attributes at DC disconnect.
  - Sign identifying AC point of connection.
  - Rapid shutdown device meets applicable requirements of NEC 690.12.
- Equipment ratings are consistent with application and installed signs on the installation, including the following:
  - Inverter has a rating as high as max voltage on PV power source sign.
  - DC-side overcurrent circuit protection devices (OCPDs) are DC rated at least as high as max voltage on sign.
  - Inverter is rated for the site AC voltage supplied and shown on the AC point of connection sign.
  - OCPD connected to the AC output of the inverter is rated at least 125% of maximum current on sign and is no larger than the maximum OCPD on the inverter listing label.
  - Sum of the main OCPD and the inverter OCPD is rated for not more than 120% of the buss bar rating.

#### DEPARTMENTAL CONTACT INFORMATION

For additional information regarding this permit process, please consult our departmental website at <https://co.jefferson.ny.us/departments/CodeEnforcement> or contact Code Enforcement at 315-785-5130.